

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7271-0554:134 Page 1 of 1

**CATEGORY:** Ionization Smoke Detector

**LISTEE:** Johnson Controls, 507 E. Michigan Street, Milwaukee, WI 53202-5211 \*  
Contact: \*James D. Kinney (414) 524-4358

**DESIGN:** Model 1351J ionization smoke detector. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as an ionization smoke detector for use with listee's listed Models B501BJ base (CSFM Listing No. 7300-0554:108) and separately listed compatible fire alarm control units.

**XLF:** 7271-1209:158

\*Rev. 06-10-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 10, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**  
**Program Manager**